

Certificate



for European Product Safety

Reference No. 1612813

Heater for mounting in ventilating duct

Type designation VFL2-Ex*x*/*, VTL2-Ex*x*/*, VRA2-Ex*x*/*

Certificate holder **VEAB Heat Tech AB**
Box 265
281 23 Hässleholm
SWEDEN

The product complies with the standard(s) EN 60335-1:2012+A11
EN 60335-2-30:2009+A11
EN 62233:2008

Date of expiry 8 February 2022

EU Directive information According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed 
Bo Berglöf Date 8 February 2017
Page 1 of 2

This certificate is issued in accordance with the terms and conditions set out in the Appendix.



Intertek Appendix

Reference No. 1612813

Technical data

Type designation	VFL2-Ex*x*/*, VTL2-Ex*x*/*, VRA2-Ex*x*/*
Rated voltage (V)	230-690
Rated power (W)	0,5 kW to 1000 kW
Frequency (Hz)	50-60
Class	I
IP-Class	66

Explanation of type designation:

First asterisk	Duct breadth (mm)
Second asterisk	Duct height (mm)
Third asterisk	Power (kW)

Manufacturing site(s) VEAB Heat Tech AB
 Stattenavägen 50
 281 23 Hässleholm
 SWEDEN

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

The instruction for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
--------------------	------------------------------------------	-------	-------------------

Signed	 Bo Berglöf	Date	8 February 2017
--------	---------------------------------------------------------------------------------------------------	------	-----------------

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

RMP