

UK-TYPE EXAMINATION CERTIFICATE

Product or Protective Systems Intended for Use in Potentially Explosive Atmospheres

UKSI 2016:1107 (as amended) – Schedule 3A, Part 1

- UK-Type Examination Certificate Number:** ITS21UKEX0246X **Issue 00**
- Product:** VFL2-Ex, VTL2-Ex & VRA2-Ex Electrical Duct Heaters
- Manufacturer:** VEAB Heat Tech AB
- Address:** Stattenavägen 50, SE-28133 Hässleholm, Sweden
- This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- Intertek Testing and Certification Limited, Approved Body number 0359, in accordance with Regulation 42 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended), certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.

The examination and test results are recorded in the confidential report 09041188A1 dated January 2012, 101933188MAN-001 dated January 2016, G102599932 dated June 2016 and 104695834CHE-001 dated 14 September 2021.
- Compliance with the Essential Health and Safety Requirements has been assured by compliance with EN IEC 60079-0:2018 and EN IEC 60079-7:2015+A1:2018 except in respect of those requirements referred to within item 14 of the Schedule.
- If the sign “X” is placed after the certificate number, it indicates that the product is subject to the special conditions of use specified in the Schedule to this certificate.
- This UK-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Regulations apply to the manufacturing process and supply of this product. These are not covered by this certificate.
- The marking of the product shall include the following:



II 2 G Ex db eb mb IIC T3 Gb
-50°C ≤ Ta ≤ +40°C

Certification Officer: _____ **Date:** 18th October 2021
M Newman

SCHEDULE:

UK-Type Examination Certificate Number: ITS21UKEX0246X Issue 00


11. Description of Product or Protective System

The VFL2-Ex, VTL2-Ex & VRA2-Ex enclosures consist of a hinged enclosure and duct which varies from KB = 200mm, KH = 200mm, KD = 270mm to KB = 3000mm, KD = 2000mm. The enclosure is manufactured from stainless steel and is used to house suitably certified Ex e terminals and Ex d temperature control, anti-condensation heater including thermostat. In addition, the heater elements are partly housed inside the enclosure and electrical connections are made here.

Their elements protrude through the enclosure wall into the air flow.

Both internal and external earthing is provided.

“Ex db” and “Ex mb” are included in the coding as the equipment utilises “Ex db” and “Ex mb” certified parts.



12. Report Number

Intertek Report: 09041188A1 dated January 2012, 101933188MAN-001 dated January 2016, G102599932 dated June 2016 and 104695834CHE-001 dated 21 September 2021.

13. Special Conditions of Certification

(a). Special Conditions of Use

- All power supplies must be fed via an interlock as indicated in the wiring diagrams of the manual.
- The duct heater must never be mounted with the enclosure placed at the bottom
- The maximum surface load on the heating elements is 1.0W/cm.
- The manufacturers operating, and maintenance instructions shall always be followed.
- Temperatures could exceed 70°C at the cable gland or 80°C at the branching point, suitably rated cable must be selected.
- No batteries or cells are to be fitted inside the enclosure.
- Heating elements shall be protected from mechanical impact.
- Suitably approved Ex eb IIC Gb -50°C ≤ Ta ≤ +40°C cable glands and blanking elements only to be used.
- The two over temperature sensors shall be fitted to power step 1 Power step 1 shall be the first to be energized when required for operation.
- Two over temperature sensors shall be fitted in the last row of the air flow direction (as shown below)
- Unit to be fitted with a current or resistance safety device per clause 5.8.6.2 of 60079-7:2015+A1:2018.

(b). Conditions of Manufacture

- A routine dielectric strength test in accordance with clause 6.1 of EN 60079-7:2015+A1:2018 shall be carried out between the case and enclosure terminals. All results must be recorded.

14. Essential Health and Safety Requirements (EHSRs)

The relevant Essential Health and Safety Requirements (EHSRs) have been identified and assessed in Intertek Report: 104695834CHE-001, dated 14 September 2021.

15. Drawings and Documents

Title:	Drawing No.:	Rev. Level:	Date:
Heater Ex Type Label layout	55323	10	2021-06-23
Duct heater VTL2-Ex General drawing	58208	3	2021-07-05
Duct heater VRA2-Ex General drawing	58207	3	2021-07-05
Duct heater VFL2-Ex General drawing	58206	3	2021-07-05
Duct heater Ex Junction box with Silicone rubber Subassembly drawing	57944	4	2021-07-05
Duct heater Ex Junction box with hinge general drawing	55910	1	2015-08-28
Duct heater VTL-Ex 0359 CE Ex II 2 G Ex de IIC T3 Gb General drawing	58218	1	2015-09-01
Duct heater VRA-Ex 0359 CE Ex II 2 G Ex de IIC T3 Gb General drawing	58217	1	2015-09-01
Duct heater VFL-Ex 0359 CE Ex II 2 G Ex de IIC T3 Gb General drawing	55902	4	2014-11-14
EX heater Wiring example	54134	6	160516
Dust heater ATEX approved Electrical connection heating element	54299	4	2021-06-28
Duct Heater VTL-Ex 0359 CE Ex II 2 G Ex de IIC T3 Gb General drawing	54742	7	2014-09-19
Duct Heater VRA-Ex 0359 CE Ex II 2 G Ex ed IIC T3 Gb General drawing	54743	7	2014-09-19
Duct Heater Ex Junction Box General drawing	55006	4	2011-12-19
Duct Heater Ex Sealing profile industrilas P/N 427051	55223	1	111017
Warning Label "Do not open when energized"	58751	-	2016-07-15
Duct Heater EX placing of temperature controller Bulb	55689	3	210312
Duct heating EX resistance Heat elements (Ω) at 20C	55478	1	2012-01-25
INSTALLATION, OPERATION AND MAINTENANCE INSTRUCTION ATEX/UKEX approved electrical air heaters for explosive gas atmospheres.	173062-04	-	As Stamped

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This Certificate is accredited under UKAS schedule 0010

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SA
Registered No 3272281 Registered Office: Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ.