

# Certificate



Intertek

for European Product Safety

Reference No. 1304319

Type designation EA 6, EA 9, EA 9TS, EA 9TSE, EA 14, EA 21, EA 30

Certificate holder **VEAB Heat Tech AB**  
**Box 265**  
**281 23 Hässleholm**  
**SWEDEN**


The product complies with the standard(s) EN 60335-1:2012  
EN 60335-2-30:2009+A11  
EN 62233:2008

Date of expiry 28 May 2019

EU Directive information The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed   
Niclas Lood Date 28 May 2014  
Page 1 of 2

This certificate is issued in accordance with the terms and conditions set out in the Appendix.

ARN

**Intertek  
Appendix**

Reference No. 1304319

*Technical data*

Type designation	EA 6, EA 9, EA 9TS, EA 9TSE, EA 14, EA 21, EA 30
Rated voltage (V)	400 3NAC
Rated power (W)	6000, 9000, 14000, 21000, 30000
Frequency (Hz)	50
Class	I
IP-Class	IP44

*Manufacturing site(s)* VEAB Heat Tech AB  
Stattenavägen 50  
281 23 Hässleholm  
SWEDEN

*Certification Body* Intertek Semko AB, Product Certification *Place* Kista - Stockholm

*Signed*  
\_\_\_\_\_  
Niclas Lood*Date* 28 May 2014

*This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.*