

# Certificate



for European Product Safety


Reference No. 1310804

## Fan heater

Type designation	ROBUST F9, ROBUST F9N
Certificate holder	<b>VEAB Heat Tech AB</b> Box 265 281 23 Hässleholm SWEDEN
The product complies with the standard(s)	EN 60335-1:2012 EN 60335-2-30:2009+A11 EN 62233:2008 SEMKO 111FF-1987, EMKO-TUB(61)N289/90
Date of expiry	28 May 2019
EU Directive information	The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed   
Niclas Lood Date 28 May 2014  
Page 1 of 2

**Intertek  
Appendix**

Reference No. 1310804

*Technical data*

Type designation	ROBUST F9
Rated voltage (V)	400
Rated power (W)	9000
Frequency (Hz)	50-60
Class	I
IP-Class	65
Product information	3AC

Type designation	ROBUST F9N
Rated voltage (V)	230
Rated power (W)	9000
Frequency (Hz)	50-60
Class	I
IP-Class	65
Product information	3AC

Manufacturing site(s)	VEAB Heat Tech AB Stattenevägen 50 281 23 Hässleholm SWEDEN
-----------------------	--

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
--------------------	--	-------	-------------------

Signed

  
\_\_\_\_\_  
Nilsas Lood

Date 28 May 2014

*This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.*